

**REZAYAT COMPANY LTD****شركة رضيات المحدودة**

Tel.: (04) 357-1241 Fax.: (04) 357-1240 Email: rcl.yanbu@rezayat.com.sa

MEMBER OF **REZAYAT GROUP**
A MEMBER OF ALREZA GROUP OF COMPANIES
Website: www.rezayat.comContract Title : **CONSTRUCTION OF PRIMARY BOYS SCHOOL IN HAIL FAISAL 2 AND PRIMARY GIRLS SCHOOL IN HAIL AL-MESHARAF**Contract No. : **PIC G-1507E****SUBMITTAL FOR**

☐ D. Drawings ☐ Shop Drawing ☒ Material
☒ Approval ☐ Verification ☐ Information
☐ Record ☐ Deviation ☐ Others

Date : **October 11, 2012**Submittal No. : **PIC G-1507E-138**ATTENTION : **ENGR. ZUHAIR ALAWI AL-SAYED**
Authorized Representative

EWR No. :

☒ First Submittal☐ Re-Submittal

Previous Submittal No. :

Subject Reference Spec.

SECTION 16050

Item Description / Subject

LOW VOLTAGE CABLES
"Red Sea Cables"

List of Attachments

A) **EWR LIST + CATALOG CUTS + TECHNICAL DATA**
 B) **SECTION 16050, SECTION 16450 + Manufacturer's Documents**

Contractor's Certification : "Having checked this submittal, we certify that it conforms to the requirements of the Contract Documents in all respects, except otherwise indicated herein."

Prepared by: **Electrical Engineer**Checked by: **QA/QC Manager**Signed by: **Acting Project Manager****ENGR. ERIC PEJI**Date: **11-Oct-12****ENGR. LEMUEL CABALLERO**Date: **11-Oct-12****ENGR. BASSAM SUBOH**Date: **11-Oct-12****Royal Commission Review / Construction Group**

☐ AR ☐ CE ☒ EE ☐ ME ☐ SE ☐ OTHER

Project Controls ☐ Cost ☐ Quantity Survey ☐ Estimate ☐ Schedule

Royal Commission / MSC Review and Approval Status

☒ (A) Work May Proceed
☐ (B) Work May Proceed - Minor Comment
☐ (C) Work May Proceed Except As Noted
☐ (D) Disapproved
☐ Acceptable With No Comment
☐ Acceptable With Minor Comments
☐ Unacceptable / Rejected
☐ Other Comments : See Below

☐ Resubmittal Not Required. Incorporate comments and proceed.
☐ Resubmittal required. Incorporate comments. Do not proceed.
☐ Submittal Incomplete. Complete and re-submit again
☐ Submittal inconsistent with contract

ATTACHMENTS:

☐ Engineering Review Comments Sheet(s).
☒ EWR List of Submitted Materials indicating the review status of submitted materials **1- SHT**
☐ Contractor Drawing Submittal Sheet(s) indicating status of submitted drawing(s).
☐ Other Enclosures / Attachments

Note : Shop Drawing Review require "Released for Construction" sticker before proceeding.

Log: **33027**

Reviewer:

FELIX EDUARDO
PRIN. ENG. ENGR.**18 OCT '12**

CSG-Supervisor:

Date

Receipt Date:

17 OCT 12**Royal Commission / MSC / Construction**

The review and approval is provided that the submittal is in compliance with the contract documents. This approval shall not be construed as an approval of a change in Contract Scope of Work. A prompt response shall be made by the contractor in writing if any comments is considered not to be within the terms of the contract.

ADDITIONAL COMMENTS:

Project File No. :

EWR No. :

Ref. No. :

CC / RF Chrono. :

For RC / MSC :

ENGR. ZUHAIR ALAWI AL-SAYED
Authorized Representative

Date :

(NOT APPLICABLE TO DRAWINGS)

PIC G-1507E

EWR NO.


C-33027

[illegible]

REVIEW STATUS :

- A - WORK MAY PROCEED - NO COMMENTS
B - WORK MAY PROCEED - MINOR COMMENTS
C - WORK MAY PROCEED EXCEPT AS NOTED (Resubmittal Required)
D - DISAPPROVED - WORK MAY NOT PROCEED (Resubmittal Required)

| | |
|-----------------|--------------------------------|
| CONTRACTOR : | <u>REZAYAT COMPANY LIMITED</u> |
| SUBMITTAL No. : | <u>PIC G-1507E-138</u> |
| DATE : | <u>11-Oct-12</u> |



AL ZAHRANI TRADING & CONTRACTING CO.

شركة الزهراني للتجارة والمقاولات

HEAD OFFICE: DAMMAM C.R. 2050011975. TEL: 8319999 FAX: 8315533 P.O. BOX 135 DAMMAM 31431 SAUDI ARABIA E-MAIL: TCO@ALZAHIRANI.COM.SA

Contract Title

CONSTRUCTION OF ROYAL COMMISSION PUBLIC HOUSING (PHASE 6)

Contract No.

PIC F-8101

SUBMITTAL FOR

☐ Shop Drawings ☒ Material ☐ Others
☒ Approval ☐ Verification ☐ Information
☐ Record ☐ Deviation ☐ Others

ATTENTION:

ENGR. HAKIM Y. DAQEEQ

SR. RESIDENT CONSTRUCTION MANAGER

☒ First Submittal ☐ Re-Submittal (Previous Sub. No.):

Subject Reference No.

16050

Item Description / Subject:

MATERIAL SUBMITTAL FOR LOW VOLTAGE POWER CABLES, WIRES AND WIRING CABLES: AS MANUFACTURED AND TO BE SUPPLIED BY RED SEA CABLES (RESCAB)

List of Attachments:

A) SUBMITTAL FOR LOW VOLTAGE POWER CABLES AND WIRES (RESCAB)
B) MANUFACTURER / SUPPLIER PREQUALIFICATION DOCUMENTS (RESCAB)

Contractor's Signature:

"Having checked this submittal, we certify that it conforms to the requirements of the Contract Documents in all respects, except otherwise indicated herein."

Checked by: QA/QC Manager

Signed by: Project Manager

ENGR. O. SANTOS

ENGR. A. FAROUK

Date: 28-NOV-2013

Date: 28-Nov-13

Royal Commission Review / Construction Support Group

☐ AR ☐ CE ☒ EE ☐ ME ☐ SE ☐ Other
Project Controls ☐ Cost ☐ Quantity Survey ☐ Estimate ☐ Schedule

Royal Commission / MSC Review and Approval Status

☐ (A) Work May proceed
☒ (B) Work May proceed - Minor Comment
☐ (C) Work May proceed Except as Noted
☐ (D) Disapproved
☐ Acceptable with no comments
☐ Acceptable with minor comments
☐ Unacceptable / Rejected
☐ Other Comments: See below

☐ Re-submittal not required. Incorporate comments and proceed.
☐ Re-submittal required. Incorporate comments. Don't proceed.
☐ Submittal incomplete. Complete & re-submit again.
☐ Submittal inconsistent with contract.

ATTACHMENTS:

☒ Engineering Review Comments Sheet(s). 1-SHT
☒ EWR List of Submitted Materials indicating the Review status submitted materials. 1-SHT
☐ Contractor Drawing submittal sheet(s) indicating status of submitted drawing(s).
☐ Other enclosures / attachments.

NOTE: Shop Drawing review require "Released for Construction" sticker before proceeding.

CSG Log #:

39550

Reviewer:

Date:

05 DEC 13

CSG Supervisor:

Date:

5/12/13

Receipt Date:

03 Dec 13

FELIX LEONARDO

PRIN. ELEC. ENGR.

RC / MSC CONSTRUCTION

The review and approval is provided conditionally that the submittal is in compliance with the contract documents. This approval shall not be construed as an approval of a change in Contract scope or price. A prompt response shall be made by the Contractor in writing if any comment is considered not to be within the terms of the Contract.

ADDITIONAL COMMENTS:

Comply with CSG comments and resubmit

Project File No.:

14.43

EWR No. / CSG Log:

Ref. Number

171

For RC/MS:

ENGR. HAKIM Y. DAQEEQ
SR. RESIDENT CONST. MANAGER

Date:

8/12/13

CC: RF/Chrono

CSG ENGINEERING REVIEW COMMENTS

Page 1 of 1

| | | |
|--|---|--|
| CONTRACT NO : PIC F-8101 | EWR NO. : C-39550 | |
| CONTR. TITLE : Construction of RC Public Housing (Phase 6) | DISCIPLINE : Electrical-CSG | |
| CONTRACTOR : AL ZAHIRANI Trading & contracting Co. | REVIEWER : F. Leonardo <i>[Signature]</i> | |
| REVIEW SUBJECT : Low Voltage Power Cables and Building Wires by RESCAB | SUPERVISOR : Ahtisham Shihwani | |
| | DATE : 05 December 2013 | |

| ITEM | REFERENCE DWG. PAR. ETC. | COMMENTS | ACTION |
|------|---|--|--------|
| EE-1 | Item # 1.1A-1.1E, 1.2A, 1.3A and 1.3B Low Voltage Power Cables and Wires | Offered low voltage power cables and building wires are technically acceptable. However, manufacturer/supplier needs to prequalify prior material approval. Submit the most recent and valid Zakat certificate. Submitted certificate is out-of-date and already expired. | |
| EE-2 | | | |
| | | | |